

Access Floor Seal At Fire Barrier Below Door Threshold

Tate Access Floors, Inc.
7510 Montevideo Road
Jessup, MD 20794
Tel (410) 799-4200
Fax (410) 799-4207



Following are Gun-grade sealants which have been used for air plenum sealing and comply with the VOC content limits of LEED EQ Credit 4.1 Low Emitting Materials: Adhesive and Sealants. Deep penetrations must be controlled by the use of back-up filler material; see sealant manufacturer's recommendations for these requirements.

Seal Bond 93 Seam and Penetration Sealant.
VOC Content: <17g/L. www.seal-bond.com

SONOLASTIC® NP 1 Elastomeric Polyurethane Sealant.
VOC Content: 43g/L. www.BuildingSystems.BASF.com

Pecora AC-20 Acrylic Latex Sealant.
VOC Content: 31 g/L. www.pecora.com

RCD Corp. #20 Clear Acrylic Adhesive Sealant.
VOC Content: <10 g/L. www.rcdmastics.com

Option 1: Attach Threshold
With Gasket On Underside

Option 2: Apply sealant or Attach
Gasket to Barrier to Seal Joints

ConCore or All Steel
Access Floor Panel

Perimeter Pedestal Support

Sheetrock Faced Fire Barrier

Fire Rated Caulk or Sealant
at Floor Slab Line

